

Certificate of Product Ratings

AHRI Certified Reference Number: 5945094

Date: 12/9/2015

Product: Split System: Air-Cooled Condensing Unit, Coil with Blower

Outdoor Unit Model Number: TSA036H4N42G

Indoor Unit Model Number: CBX25UH-036-230-*

Manufacturer: LENNOX INDUSTRIES, INC.

Trade/Brand name: T-CLASS

Region:

Region Note: Central air conditioners manufactured prior to January 1, 2015, are eligible to be installed in all regions until June 30, 2016. Beginning July 1, 2016, central air conditioners can only be installed in region(s) for which they meet the regional efficiency requirement.

Series name: T-CLASS

Manufacturer responsible for the rating of this system combination is LENNOX INDUSTRIES, INC.

Rated as follows in accordance with AHRI Standard 210/240-2008 for Unitary Air-Conditioning and Air-Source Heat Pump Equipment and subject to verification of rating accuracy by AHRI-sponsored, independent, third party testing:

Cooling Capacity (Btuh):	33400
EER Rating (Cooling):	12.00
SEER Rating (Cooling):	14.00
IEER Rating (Cooling):	

AHRI CERTIFIED®
www.ahridirectory.org

* Ratings followed by an asterisk (*) indicate a voluntary rerate of previously published data, unless accompanied with a WAS, which indicates an involuntary rerate.

DISCLAIMER

AHRI does not endorse the product(s) listed on this Certificate and makes no representations, warranties or guarantees as to, and assumes no responsibility for, the product(s) listed on this Certificate. AHRI expressly disclaims all liability for damages of any kind arising out of the use or performance of the product(s), or the unauthorized alteration of data listed on this Certificate. Certified ratings are valid only for models and configurations listed in the directory at www.ahridirectory.org.

TERMS AND CONDITIONS

This Certificate and its contents are proprietary products of AHRI. This Certificate shall only be used for individual, personal and confidential reference purposes. The contents of this Certificate may not, in whole or in part, be reproduced; copied; disseminated; entered into a computer database; or otherwise utilized, in any form or manner or by any means, except for the user's individual, personal and confidential reference.

CERTIFICATE VERIFICATION

The information for the model cited on this certificate can be verified at www.ahridirectory.org, click on "Verify Certificate" link and enter the AHRI Certified Reference Number and the date on which the certificate was issued, which is listed above, and the Certificate No., which is listed at bottom right.

©2014 Air-Conditioning, Heating, and Refrigeration Institute



we make life better™

CERTIFICATE NO.:

130941119678396609

Certificate of Product Ratings

AHRI Certified Reference Number: 5945095

Date: 12/9/2015

Product: Split System: Air-Cooled Condensing Unit, Coil with Blower

Outdoor Unit Model Number: TSA036H4N42Y

Indoor Unit Model Number: CBX25UH-036-230-*

Manufacturer: LENNOX INDUSTRIES, INC.

Trade/Brand name: T-CLASS

Region:

Region Note: Central air conditioners manufactured prior to January 1, 2015, are eligible to be installed in all regions until June 30, 2016. Beginning July 1, 2016, central air conditioners can only be installed in region(s) for which they meet the regional efficiency requirement.

Series name: T-CLASS

Manufacturer responsible for the rating of this system combination is LENNOX INDUSTRIES, INC.

Rated as follows in accordance with AHRI Standard 210/240-2008 for Unitary Air-Conditioning and Air-Source Heat Pump Equipment and subject to verification of rating accuracy by AHRI-sponsored, independent, third party testing:

Cooling Capacity (Btuh):	33400
EER Rating (Cooling):	12.00
SEER Rating (Cooling):	14.00
IEER Rating (Cooling):	

AHRI CERTIFIED®
www.ahridirectory.org

* Ratings followed by an asterisk (*) indicate a voluntary rerate of previously published data, unless accompanied with a WAS, which indicates an involuntary rerate.

DISCLAIMER

AHRI does not endorse the product(s) listed on this Certificate and makes no representations, warranties or guarantees as to, and assumes no responsibility for, the product(s) listed on this Certificate. AHRI expressly disclaims all liability for damages of any kind arising out of the use or performance of the product(s), or the unauthorized alteration of data listed on this Certificate. Certified ratings are valid only for models and configurations listed in the directory at www.ahridirectory.org.

TERMS AND CONDITIONS

This Certificate and its contents are proprietary products of AHRI. This Certificate shall only be used for individual, personal and confidential reference purposes. The contents of this Certificate may not, in whole or in part, be reproduced; copied; disseminated; entered into a computer database; or otherwise utilized, in any form or manner or by any means, except for the user's individual, personal and confidential reference.

CERTIFICATE VERIFICATION

The information for the model cited on this certificate can be verified at www.ahridirectory.org, click on "Verify Certificate" link and enter the AHRI Certified Reference Number and the date on which the certificate was issued, which is listed above, and the Certificate No., which is listed at bottom right.

©2014 Air-Conditioning, Heating, and Refrigeration Institute



we make life better™

CERTIFICATE NO.:

130941118708026849

Certificate of Product Ratings

AHRI Certified Reference Number: 5945086

Date: 12/7/2015

Product: Split System: Air-Cooled Condensing Unit, Coil with Blower

Outdoor Unit Model Number: TSA036S4N*G

Indoor Unit Model Number: CBX25UH-036-230-*

Manufacturer: LENNOX INDUSTRIES, INC.

Trade/Brand name: T-CLASS

Region:

Region Note: Central air conditioners manufactured prior to January 1, 2015, are eligible to be installed in all regions until June 30, 2016. Beginning July 1, 2016, central air conditioners can only be installed in region(s) for which they meet the regional efficiency requirement.

Series name: T-CLASS

Manufacturer responsible for the rating of this system combination is LENNOX INDUSTRIES, INC.

Rated as follows in accordance with AHRI Standard 210/240-2008 for Unitary Air-Conditioning and Air-Source Heat Pump Equipment and subject to verification of rating accuracy by AHRI-sponsored, independent, third party testing:

Cooling Capacity (Btuh):	34200
EER Rating (Cooling):	11.00
SEER Rating (Cooling):	13.00
IEER Rating (Cooling):	

AHRI CERTIFIED®
www.ahridirectory.org

* Ratings followed by an asterisk (*) indicate a voluntary rerate of previously published data, unless accompanied with a WAS, which indicates an involuntary rerate.

DISCLAIMER

AHRI does not endorse the product(s) listed on this Certificate and makes no representations, warranties or guarantees as to, and assumes no responsibility for, the product(s) listed on this Certificate. AHRI expressly disclaims all liability for damages of any kind arising out of the use or performance of the product(s), or the unauthorized alteration of data listed on this Certificate. Certified ratings are valid only for models and configurations listed in the directory at www.ahridirectory.org.

TERMS AND CONDITIONS

This Certificate and its contents are proprietary products of AHRI. This Certificate shall only be used for individual, personal and confidential reference purposes. The contents of this Certificate may not, in whole or in part, be reproduced; copied; disseminated; entered into a computer database; or otherwise utilized, in any form or manner or by any means, except for the user's individual, personal and confidential reference.

CERTIFICATE VERIFICATION

The information for the model cited on this certificate can be verified at www.ahridirectory.org, click on "Verify Certificate" link and enter the AHRI Certified Reference Number and the date on which the certificate was issued, which is listed above, and the Certificate No., which is listed at bottom right.

©2014 Air-Conditioning, Heating, and Refrigeration Institute



we make life better™

CERTIFICATE NO.:

130939383112104539

Certificate of Product Ratings

AHRI Certified Reference Number: 5945087

Date: 11/28/2015

Product: Split System: Air-Cooled Condensing Unit, Coil with Blower

Outdoor Unit Model Number: TSA036S4N*Y

Indoor Unit Model Number: CBX25UH-036-230-*

Manufacturer: LENNOX INDUSTRIES, INC.

Trade/Brand name: T-CLASS

Region:

Region Note: Central air conditioners manufactured prior to January 1, 2015, are eligible to be installed in all regions until June 30, 2016. Beginning July 1, 2016, central air conditioners can only be installed in region(s) for which they meet the regional efficiency requirement.

Series name: T-CLASS

Manufacturer responsible for the rating of this system combination is LENNOX INDUSTRIES, INC.

Rated as follows in accordance with AHRI Standard 210/240-2008 for Unitary Air-Conditioning and Air-Source Heat Pump Equipment and subject to verification of rating accuracy by AHRI-sponsored, independent, third party testing:

Cooling Capacity (Btuh):	34200
EER Rating (Cooling):	11.00
SEER Rating (Cooling):	13.00
IEER Rating (Cooling):	

AHRI CERTIFIED®
www.ahridirectory.org

* Ratings followed by an asterisk (*) indicate a voluntary rerate of previously published data, unless accompanied with a WAS, which indicates an involuntary rerate.

DISCLAIMER

AHRI does not endorse the product(s) listed on this Certificate and makes no representations, warranties or guarantees as to, and assumes no responsibility for, the product(s) listed on this Certificate. AHRI expressly disclaims all liability for damages of any kind arising out of the use or performance of the product(s), or the unauthorized alteration of data listed on this Certificate. Certified ratings are valid only for models and configurations listed in the directory at www.ahridirectory.org.

TERMS AND CONDITIONS

This Certificate and its contents are proprietary products of AHRI. This Certificate shall only be used for individual, personal and confidential reference purposes. The contents of this Certificate may not, in whole or in part, be reproduced; copied; disseminated; entered into a computer database; or otherwise utilized, in any form or manner or by any means, except for the user's individual, personal and confidential reference.

CERTIFICATE VERIFICATION

The information for the model cited on this certificate can be verified at www.ahridirectory.org, click on "Verify Certificate" link and enter the AHRI Certified Reference Number and the date on which the certificate was issued, which is listed above, and the Certificate No., which is listed at bottom right.

©2014 Air-Conditioning, Heating, and Refrigeration Institute



we make life better™

CERTIFICATE NO.:

130932077003178553

Certificate of Product Ratings

AHRI Certified Reference Number: 5945098

Date: 12/9/2015

Product: Split System: Air-Cooled Condensing Unit, Coil with Blower

Outdoor Unit Model Number: TSA048H4N4*G

Indoor Unit Model Number: CBX25UH-048-230-*

Manufacturer: LENNOX INDUSTRIES, INC.

Trade/Brand name: T-CLASS

Region:

Region Note: Central air conditioners manufactured prior to January 1, 2015, are eligible to be installed in all regions until June 30, 2016. Beginning July 1, 2016, central air conditioners can only be installed in region(s) for which they meet the regional efficiency requirement.

Series name: T-CLASS

Manufacturer responsible for the rating of this system combination is LENNOX INDUSTRIES, INC.

Rated as follows in accordance with AHRI Standard 210/240-2008 for Unitary Air-Conditioning and Air-Source Heat Pump Equipment and subject to verification of rating accuracy by AHRI-sponsored, independent, third party testing:

Cooling Capacity (Btuh):	48500
EER Rating (Cooling):	12.00
SEER Rating (Cooling):	14.00
IEER Rating (Cooling):	

AHRI CERTIFIED®
www.ahridirectory.org

* Ratings followed by an asterisk (*) indicate a voluntary rerate of previously published data, unless accompanied with a WAS, which indicates an involuntary rerate.

DISCLAIMER

AHRI does not endorse the product(s) listed on this Certificate and makes no representations, warranties or guarantees as to, and assumes no responsibility for, the product(s) listed on this Certificate. AHRI expressly disclaims all liability for damages of any kind arising out of the use or performance of the product(s), or the unauthorized alteration of data listed on this Certificate. Certified ratings are valid only for models and configurations listed in the directory at www.ahridirectory.org.

TERMS AND CONDITIONS

This Certificate and its contents are proprietary products of AHRI. This Certificate shall only be used for individual, personal and confidential reference purposes. The contents of this Certificate may not, in whole or in part, be reproduced; copied; disseminated; entered into a computer database; or otherwise utilized, in any form or manner or by any means, except for the user's individual, personal and confidential reference.

CERTIFICATE VERIFICATION

The information for the model cited on this certificate can be verified at www.ahridirectory.org, click on "Verify Certificate" link and enter the AHRI Certified Reference Number and the date on which the certificate was issued, which is listed above, and the Certificate No., which is listed at bottom right.

©2014 Air-Conditioning, Heating, and Refrigeration Institute



we make life better™

CERTIFICATE NO.:

130941120891670825

Certificate of Product Ratings

AHRI Certified Reference Number: 5945099

Date: 12/9/2015

Product: Split System: Air-Cooled Condensing Unit, Coil with Blower

Outdoor Unit Model Number: TSA048H4N4*Y

Indoor Unit Model Number: CBX25UH-048-230-*

Manufacturer: LENNOX INDUSTRIES, INC.

Trade/Brand name: T-CLASS

Region:

Region Note: Central air conditioners manufactured prior to January 1, 2015, are eligible to be installed in all regions until June 30, 2016. Beginning July 1, 2016, central air conditioners can only be installed in region(s) for which they meet the regional efficiency requirement.

Series name: T-CLASS

Manufacturer responsible for the rating of this system combination is LENNOX INDUSTRIES, INC.

Rated as follows in accordance with AHRI Standard 210/240-2008 for Unitary Air-Conditioning and Air-Source Heat Pump Equipment and subject to verification of rating accuracy by AHRI-sponsored, independent, third party testing:

Cooling Capacity (Btuh):	48500
EER Rating (Cooling):	12.00
SEER Rating (Cooling):	14.00
IEER Rating (Cooling):	

AHRI CERTIFIED®
www.ahridirectory.org

* Ratings followed by an asterisk (*) indicate a voluntary rerate of previously published data, unless accompanied with a WAS, which indicates an involuntary rerate.

DISCLAIMER

AHRI does not endorse the product(s) listed on this Certificate and makes no representations, warranties or guarantees as to, and assumes no responsibility for, the product(s) listed on this Certificate. AHRI expressly disclaims all liability for damages of any kind arising out of the use or performance of the product(s), or the unauthorized alteration of data listed on this Certificate. Certified ratings are valid only for models and configurations listed in the directory at www.ahridirectory.org.

TERMS AND CONDITIONS

This Certificate and its contents are proprietary products of AHRI. This Certificate shall only be used for individual, personal and confidential reference purposes. The contents of this Certificate may not, in whole or in part, be reproduced; copied; disseminated; entered into a computer database; or otherwise utilized, in any form or manner or by any means, except for the user's individual, personal and confidential reference.

CERTIFICATE VERIFICATION

The information for the model cited on this certificate can be verified at www.ahridirectory.org, click on "Verify Certificate" link and enter the AHRI Certified Reference Number and the date on which the certificate was issued, which is listed above, and the Certificate No., which is listed at bottom right.

©2014 Air-Conditioning, Heating, and Refrigeration Institute



we make life better™

CERTIFICATE NO.:

130941117368698169

Certificate of Product Ratings

AHRI Certified Reference Number: 5945090

Date: 12/7/2015

Product: Split System: Air-Cooled Condensing Unit, Coil with Blower

Outdoor Unit Model Number: TSA048S4N*G

Indoor Unit Model Number: CBX25UH-048-230-*

Manufacturer: LENNOX INDUSTRIES, INC.

Trade/Brand name: T-CLASS

Region:

Region Note: Central air conditioners manufactured prior to January 1, 2015, are eligible to be installed in all regions until June 30, 2016. Beginning July 1, 2016, central air conditioners can only be installed in region(s) for which they meet the regional efficiency requirement.

Series name: T-CLASS

Manufacturer responsible for the rating of this system combination is LENNOX INDUSTRIES, INC.

Rated as follows in accordance with AHRI Standard 210/240-2008 for Unitary Air-Conditioning and Air-Source Heat Pump Equipment and subject to verification of rating accuracy by AHRI-sponsored, independent, third party testing:

Cooling Capacity (Btuh):	48500
EER Rating (Cooling):	11.50
SEER Rating (Cooling):	14.00
IEER Rating (Cooling):	

AHRI CERTIFIED®
www.ahridirectory.org

* Ratings followed by an asterisk (*) indicate a voluntary rerate of previously published data, unless accompanied with a WAS, which indicates an involuntary rerate.

DISCLAIMER

AHRI does not endorse the product(s) listed on this Certificate and makes no representations, warranties or guarantees as to, and assumes no responsibility for, the product(s) listed on this Certificate. AHRI expressly disclaims all liability for damages of any kind arising out of the use or performance of the product(s), or the unauthorized alteration of data listed on this Certificate. Certified ratings are valid only for models and configurations listed in the directory at www.ahridirectory.org.

TERMS AND CONDITIONS

This Certificate and its contents are proprietary products of AHRI. This Certificate shall only be used for individual, personal and confidential reference purposes. The contents of this Certificate may not, in whole or in part, be reproduced; copied; disseminated; entered into a computer database; or otherwise utilized, in any form or manner or by any means, except for the user's individual, personal and confidential reference.

CERTIFICATE VERIFICATION

The information for the model cited on this certificate can be verified at www.ahridirectory.org, click on "Verify Certificate" link and enter the AHRI Certified Reference Number and the date on which the certificate was issued, which is listed above, and the Certificate No., which is listed at bottom right.

©2014 Air-Conditioning, Heating, and Refrigeration Institute



we make life better™

CERTIFICATE NO.:

130939386403093299

Certificate of Product Ratings

AHRI Certified Reference Number: 5945091

Date: 12/7/2015

Product: Split System: Air-Cooled Condensing Unit, Coil with Blower

Outdoor Unit Model Number: TSA048S4N*Y

Indoor Unit Model Number: CBX25UH-048-230-*

Manufacturer: LENNOX INDUSTRIES, INC.

Trade/Brand name: T-CLASS

Region:

Region Note: Central air conditioners manufactured prior to January 1, 2015, are eligible to be installed in all regions until June 30, 2016. Beginning July 1, 2016, central air conditioners can only be installed in region(s) for which they meet the regional efficiency requirement.

Series name: T-CLASS

Manufacturer responsible for the rating of this system combination is LENNOX INDUSTRIES, INC.

Rated as follows in accordance with AHRI Standard 210/240-2008 for Unitary Air-Conditioning and Air-Source Heat Pump Equipment and subject to verification of rating accuracy by AHRI-sponsored, independent, third party testing:

Cooling Capacity (Btuh):	48500
EER Rating (Cooling):	11.50
SEER Rating (Cooling):	14.00
IEER Rating (Cooling):	

AHRI CERTIFIED®
www.ahridirectory.org

* Ratings followed by an asterisk (*) indicate a voluntary rerate of previously published data, unless accompanied with a WAS, which indicates an involuntary rerate.

DISCLAIMER

AHRI does not endorse the product(s) listed on this Certificate and makes no representations, warranties or guarantees as to, and assumes no responsibility for, the product(s) listed on this Certificate. AHRI expressly disclaims all liability for damages of any kind arising out of the use or performance of the product(s), or the unauthorized alteration of data listed on this Certificate. Certified ratings are valid only for models and configurations listed in the directory at www.ahridirectory.org.

TERMS AND CONDITIONS

This Certificate and its contents are proprietary products of AHRI. This Certificate shall only be used for individual, personal and confidential reference purposes. The contents of this Certificate may not, in whole or in part, be reproduced; copied; disseminated; entered into a computer database; or otherwise utilized, in any form or manner or by any means, except for the user's individual, personal and confidential reference.

CERTIFICATE VERIFICATION

The information for the model cited on this certificate can be verified at www.ahridirectory.org, click on "Verify Certificate" link and enter the AHRI Certified Reference Number and the date on which the certificate was issued, which is listed above, and the Certificate No., which is listed at bottom right.

©2014 Air-Conditioning, Heating, and Refrigeration Institute



we make life better™

CERTIFICATE NO.:

130939385221488707

Certificate of Product Ratings

AHRI Certified Reference Number: 5945100

Date: 12/9/2015

Product: Split System: Air-Cooled Condensing Unit, Coil with Blower

Outdoor Unit Model Number: TSA060H4N4*G

Indoor Unit Model Number: CBX25UH-060-230-*

Manufacturer: LENNOX INDUSTRIES, INC.

Trade/Brand name: T-CLASS

Region:

Region Note: Central air conditioners manufactured prior to January 1, 2015, are eligible to be installed in all regions until June 30, 2016. Beginning July 1, 2016, central air conditioners can only be installed in region(s) for which they meet the regional efficiency requirement.

Series name: T-CLASS

Manufacturer responsible for the rating of this system combination is LENNOX INDUSTRIES, INC.

Rated as follows in accordance with AHRI Standard 210/240-2008 for Unitary Air-Conditioning and Air-Source Heat Pump Equipment and subject to verification of rating accuracy by AHRI-sponsored, independent, third party testing:

Cooling Capacity (Btuh):	57000
EER Rating (Cooling):	12.00
SEER Rating (Cooling):	14.00
IEER Rating (Cooling):	

AHRI CERTIFIED®
www.ahridirectory.org

* Ratings followed by an asterisk (*) indicate a voluntary rerate of previously published data, unless accompanied with a WAS, which indicates an involuntary rerate.

DISCLAIMER

AHRI does not endorse the product(s) listed on this Certificate and makes no representations, warranties or guarantees as to, and assumes no responsibility for, the product(s) listed on this Certificate. AHRI expressly disclaims all liability for damages of any kind arising out of the use or performance of the product(s), or the unauthorized alteration of data listed on this Certificate. Certified ratings are valid only for models and configurations listed in the directory at www.ahridirectory.org.

TERMS AND CONDITIONS

This Certificate and its contents are proprietary products of AHRI. This Certificate shall only be used for individual, personal and confidential reference purposes. The contents of this Certificate may not, in whole or in part, be reproduced; copied; disseminated; entered into a computer database; or otherwise utilized, in any form or manner or by any means, except for the user's individual, personal and confidential reference.

CERTIFICATE VERIFICATION

The information for the model cited on this certificate can be verified at www.ahridirectory.org, click on "Verify Certificate" link and enter the AHRI Certified Reference Number and the date on which the certificate was issued, which is listed above, and the Certificate No., which is listed at bottom right.

©2014 Air-Conditioning, Heating, and Refrigeration Institute



we make life better™

CERTIFICATE NO.:

130941122758618561

Certificate of Product Ratings

AHRI Certified Reference Number: 5945101

Date: 12/9/2015

Product: Split System: Air-Cooled Condensing Unit, Coil with Blower

Outdoor Unit Model Number: TSA060H4N4*Y

Indoor Unit Model Number: CBX25UH-060-230-*

Manufacturer: LENNOX INDUSTRIES, INC.

Trade/Brand name: T-CLASS

Region:

Region Note: Central air conditioners manufactured prior to January 1, 2015, are eligible to be installed in all regions until June 30, 2016. Beginning July 1, 2016, central air conditioners can only be installed in region(s) for which they meet the regional efficiency requirement.

Series name: T-CLASS

Manufacturer responsible for the rating of this system combination is LENNOX INDUSTRIES, INC.

Rated as follows in accordance with AHRI Standard 210/240-2008 for Unitary Air-Conditioning and Air-Source Heat Pump Equipment and subject to verification of rating accuracy by AHRI-sponsored, independent, third party testing:

Cooling Capacity (Btuh):	57000
EER Rating (Cooling):	12.00
SEER Rating (Cooling):	14.00
IEER Rating (Cooling):	

AHRI CERTIFIED®
www.ahridirectory.org

* Ratings followed by an asterisk (*) indicate a voluntary rerate of previously published data, unless accompanied with a WAS, which indicates an involuntary rerate.

DISCLAIMER

AHRI does not endorse the product(s) listed on this Certificate and makes no representations, warranties or guarantees as to, and assumes no responsibility for, the product(s) listed on this Certificate. AHRI expressly disclaims all liability for damages of any kind arising out of the use or performance of the product(s), or the unauthorized alteration of data listed on this Certificate. Certified ratings are valid only for models and configurations listed in the directory at www.ahridirectory.org.

TERMS AND CONDITIONS

This Certificate and its contents are proprietary products of AHRI. This Certificate shall only be used for individual, personal and confidential reference purposes. The contents of this Certificate may not, in whole or in part, be reproduced; copied; disseminated; entered into a computer database; or otherwise utilized, in any form or manner or by any means, except for the user's individual, personal and confidential reference.

CERTIFICATE VERIFICATION

The information for the model cited on this certificate can be verified at www.ahridirectory.org, click on "Verify Certificate" link and enter the AHRI Certified Reference Number and the date on which the certificate was issued, which is listed above, and the Certificate No., which is listed at bottom right.

©2014 Air-Conditioning, Heating, and Refrigeration Institute



we make life better™

CERTIFICATE NO.:

130941121771555945

Certificate of Product Ratings

AHRI Certified Reference Number: 5945092

Date: 12/7/2015

Product: Split System: Air-Cooled Condensing Unit, Coil with Blower

Outdoor Unit Model Number: TSA060S4N*G

Indoor Unit Model Number: CBX25UH-060-230-*

Manufacturer: LENNOX INDUSTRIES, INC.

Trade/Brand name: T-CLASS

Region:

Region Note: Central air conditioners manufactured prior to January 1, 2015, are eligible to be installed in all regions until June 30, 2016. Beginning July 1, 2016, central air conditioners can only be installed in region(s) for which they meet the regional efficiency requirement.

Series name: T-CLASS

Manufacturer responsible for the rating of this system combination is LENNOX INDUSTRIES, INC.

Rated as follows in accordance with AHRI Standard 210/240-2008 for Unitary Air-Conditioning and Air-Source Heat Pump Equipment and subject to verification of rating accuracy by AHRI-sponsored, independent, third party testing:

Cooling Capacity (Btuh):	60000
EER Rating (Cooling):	11.00
SEER Rating (Cooling):	13.50
IEER Rating (Cooling):	

AHRI CERTIFIED®
www.ahridirectory.org

* Ratings followed by an asterisk (*) indicate a voluntary rerate of previously published data, unless accompanied with a WAS, which indicates an involuntary rerate.

DISCLAIMER

AHRI does not endorse the product(s) listed on this Certificate and makes no representations, warranties or guarantees as to, and assumes no responsibility for, the product(s) listed on this Certificate. AHRI expressly disclaims all liability for damages of any kind arising out of the use or performance of the product(s), or the unauthorized alteration of data listed on this Certificate. Certified ratings are valid only for models and configurations listed in the directory at www.ahridirectory.org.

TERMS AND CONDITIONS

This Certificate and its contents are proprietary products of AHRI. This Certificate shall only be used for individual, personal and confidential reference purposes. The contents of this Certificate may not, in whole or in part, be reproduced; copied; disseminated; entered into a computer database; or otherwise utilized, in any form or manner or by any means, except for the user's individual, personal and confidential reference.

CERTIFICATE VERIFICATION

The information for the model cited on this certificate can be verified at www.ahridirectory.org, click on "Verify Certificate" link and enter the AHRI Certified Reference Number and the date on which the certificate was issued, which is listed above, and the Certificate No., which is listed at bottom right.

©2014 Air-Conditioning, Heating, and Refrigeration Institute



we make life better™

CERTIFICATE NO.:

130939389941042723

Certificate of Product Ratings

AHRI Certified Reference Number: 5945093

Date: 12/7/2015

Product: Split System: Air-Cooled Condensing Unit, Coil with Blower

Outdoor Unit Model Number: TSA060S4N*Y

Indoor Unit Model Number: CBX25UH-060-230-*

Manufacturer: LENNOX INDUSTRIES, INC.

Trade/Brand name: T-CLASS

Region:

Region Note: Central air conditioners manufactured prior to January 1, 2015, are eligible to be installed in all regions until June 30, 2016. Beginning July 1, 2016, central air conditioners can only be installed in region(s) for which they meet the regional efficiency requirement.

Series name: T-CLASS

Manufacturer responsible for the rating of this system combination is LENNOX INDUSTRIES, INC.

Rated as follows in accordance with AHRI Standard 210/240-2008 for Unitary Air-Conditioning and Air-Source Heat Pump Equipment and subject to verification of rating accuracy by AHRI-sponsored, independent, third party testing:

Cooling Capacity (Btuh):	60000
EER Rating (Cooling):	11.00
SEER Rating (Cooling):	13.50
IEER Rating (Cooling):	

AHRI CERTIFIED®
www.ahridirectory.org

* Ratings followed by an asterisk (*) indicate a voluntary rerate of previously published data, unless accompanied with a WAS, which indicates an involuntary rerate.

DISCLAIMER

AHRI does not endorse the product(s) listed on this Certificate and makes no representations, warranties or guarantees as to, and assumes no responsibility for, the product(s) listed on this Certificate. AHRI expressly disclaims all liability for damages of any kind arising out of the use or performance of the product(s), or the unauthorized alteration of data listed on this Certificate. Certified ratings are valid only for models and configurations listed in the directory at www.ahridirectory.org.

TERMS AND CONDITIONS

This Certificate and its contents are proprietary products of AHRI. This Certificate shall only be used for individual, personal and confidential reference purposes. The contents of this Certificate may not, in whole or in part, be reproduced; copied; disseminated; entered into a computer database; or otherwise utilized, in any form or manner or by any means, except for the user's individual, personal and confidential reference.

CERTIFICATE VERIFICATION

The information for the model cited on this certificate can be verified at www.ahridirectory.org, click on "Verify Certificate" link and enter the AHRI Certified Reference Number and the date on which the certificate was issued, which is listed above, and the Certificate No., which is listed at bottom right.

©2014 Air-Conditioning, Heating, and Refrigeration Institute



we make life better™

CERTIFICATE NO.:

130939387392340027